

**ATTACHMENT 3  
PLATFORM ELLY  
NON-CONTACT COOLING WATER CHLORINE RESULTS  
April 1, 2021 through June 30, 2021**

<u>Discharge</u>	<u>Measurement Frequency</u>	<u>Average Monthly Limit <sup>1</sup> Post Dilution</u> (mg/l)	<u>Maximum Daily Limit <sup>1</sup> Post Dilution</u> (mg/l)	<u>Result Post Dilution</u> (mg/l)	<u>End-of-Pipe Concentration</u> (mg/l) EPA Method 330.5	<u>EPA Plumes Dilution</u>
009 Non-contact Cooling Water 4/27/2021	Once/Quarter	0.00585	0.0102	0.0004	0.12	277:1

<sup>1</sup> Limits are post-dilution as listed in Appendix C of the Permit.